

Government of Karnataka
DISTRICT SURVEILLANCE UNIT, MYSORE

NO.DSU-DPHL/MYS/156/24-25

DATE: 12.07.2024

TO,

THE PRINCIPAL

ST. MARY'S ENGLISH SCHOOL

T.NARASIPURA, MYSURU -571124

BACTERIOLOGICAL WATER TESTING REPORT - MPN METHOD

WATER SAMPLES SUBMITTED ON 09.7.2024

SL. NO	SOURCE	PLACE OF COLLECTION	TIME OF COLLECTION	Most Probable No.of Coliform bacilli Per 100ml	RESULT
1	T.NARASIPURA MUNICIPAL SUPPLY TAP WATER	SCHOOL GROUND	9.50 AM	<1	POTABLE
2	RO PLANT	DRINKING WATER FROM RO PLANT	10.15 AM	<1	POTABLE

Interpretation

MOST PROBABLE NUMBER OF COLIFORMS IN 100ML WATER	RESULT
0	EXCELLENT
1 TO 3	SATISFACTORY
3 TO 9	DOUBTFUL
>/= 10	UNSATISFACTORY


DISTRICT SURVEILLANCE OFFICER
DISTRICT SURVEILLANCE UNIT
MYSURU DISTRICT